



A Tradition of Stewardship
A Commitment to Service

CAL FIRE **NAPA COUNTY** **FIRE DEPARTMENT**

FIRE MARSHAL'S OFFICE **DEVELOPMENT GUIDELINES**

Version: November 16, 2016

XI. FIRE DEPARTMENT ACCESS

1. A secure key entry system shall be required for all commercial facilities and security gates in the Napa County.
2. The gate access Knox key switch is #3501 or #3502.
3. Knox cabinets are required to be mounted at the driveway entrance on the right hand side and shall be mounted 3 to 5 feet to the top of the box. Knox Cabinet #1308 with weather proof housing #1201.
4. Ordering from Knox Co can be done via the KNOX website @ www.knoxbox.com or calling, 800-552-5669, use the department code #PS-01-0176-03-82 or specify **CAL FIRE/NAPA CO FIRE.**